

Book ✓



INSPECTORATE

QUALITY CERTIFICATE

Vessel	TRANSFER	Port	PORTSMOUTH, NH	Report	PL05-746
Customer	SPRAGUE ENERGY	Date	December 30, 2005	Ref. No.	
Operation	ANALYSIS	Terminal	SPRAGUE GOSLING ROAD	Ref. No.	AS BELOW

Material being tested

#6 FUEL (2.0%)

Description of sample source

TANK 1

Samples Drawn by (company)

INSPECTORATE AMERICA

Samples Tested by (company)

INSPECTORATE AMERICA

Tests being Performed	Test method	Minimum	Maximum	Sample Result
Gravity, Api	D-5002	10.1		
Upper 033127				10.2
Middle 033120				10.1
Lower 033121				10.2
Sulfur, Wt %	D-4294		2.00	
Upper 033127				1.99
Middle 033120				2.00
Lower 033121				2.00
Viscosity, cSt @122F	D-445			
Upper 033127				223
Middle 033120				223
Lower 033121				222
SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.				

DAVID CAWOOD

Inspectorate America So Portland, Me